
NOTES:

- 1 Service saddle, SS straps, CC threads Installed per manufacturer's recommendations. All main types: Smith Blair 317
- (2) Corporation Stop: Ford FB 1000-4-Q 1"
- Service tubing: Type K copper soft 1"
- (4) Ford male adapter C84-44-Q 1"
- Meter box valve:
 5 = Ford Angle Stop BA-11-444W 1"
 5A = Ford Straight Stop B11-444W 1"

- (6) Meter nipple C38-44-2-625 1"
- 8 Meter box and lid: Old Castle meter box, CI lid with Reader #36





CITY OF BRYAN STRAIGHT OR ANGLE TAP - 1"

DATE

JULY 2016

B/CS UNIFIED STANDARD DETAIL

DETAIL NO.

W6-01

