


- (MANUALLY CONSOLIDATE AT OPTIMUM MOISTURE)

NON -STRUCTURAL

W4-02



- RELATIVE COMPACTION SHALL BE TESTED IN THE PRESENCE OF THE CITY ENGINEER.
- ALL TRENCHES SHALL BE BACK FILLED AND TEMPO PAVING OR PLATING PLACED AT THE END OF EACH

## BEDDING AND TRENCH FOR DI PIPE & PVC PIPE

B(MANUALLY CONSOLIDAT

AREAS TO BE PAVED

OR STREETS TO BE

RECONSTRUCTED

GENERAL NOTES:

ALL EROSION CONTROL MEASURES SHOULD BE CLEANED OF SILT AFTER EVERY RAIN.

SHEET 1 OF 2

CITY OF BRYAN

STANDARD WATER DETAILS

BRYAN

DRAWN BY: K.L. ATE: APR 2024 ALE: NTS

APPROVED: W. P. K

