


NOTES:

- ① Service saddle, SS straps, CC threads
Installed per manufacturer's
recommendations. All main types:
Smith Blair 317
- ② Corporation Stop: Ford FB 1000-7-Q (cc thread) - 2"
- ③ Service tubing: Type K copper - soft - 2"
- ④ Ford male adapter - C84- 77 Q - 2"
- ⑤ Meter box valve:
5= Ford Angle Stop - BA -11-777W - 2"
5A = Ford Straight Stop - B11-777W - 2"
- ⑥ Brass nipple I.P.S. - 2"x3"
- ⑦ Meter Flange - CF31 - 77 - 2"
- ⑧ Meter box and lid:
Old Castle/Christy meter box and lid:
- B65 Utility Box
- N09R Concrete Lid Marked "Water"
with Flex-Net Sensus Probe Hole



CITY OF BRYAN
The Good Life, Texas Style.

**CITY OF BRYAN
STRAIGHT OR ANGLE TAP 2"**

DATE

APR 2024

**B/CS UNIFIED
STANDARD DETAIL**

DETAIL NO.

W6-03



CITY OF COLLEGE STATION